

FIRE SAFETY CERTIFICATION

PRODUCT APPROVAL



No

APF-1692

LGAI TECHNOLOGICAL CENTER S.A. (APPLUS), under the requirements of its SPC-102 certifies:

Product range	"ARMO-JR 50"	
Company	BVN - BAHÇIVAN ELEKTRIK MOTOR SAN. VE TIC. LTD. ŞTI. Ömerli Mah. Hadimköy-Istanbul Cd. No: 147 34555 Arnavutköy / Istanbul / Türkiye	
Manufactured	BNV - BAHÇIVAN ELEKTRIK MOTOR SAN. VE TIC. LTD. ŞTI. Ömerli Mah. Hadimköy-Istanbul Cd. No: 147 34555 Arnavutköy / Istanbul / Türkiye	
Standard Reference	EN 12101-3:2015 "Smoke and heat control systems. Part 3: specification for powered smoke and heat control ventilators (fans)".	
Product Details and Test Report	Please check at the technical annex and the test report and classification report no 19-20704-2384 and IC-19-20704-2384	



Valid until June 2020

Bellaterra, 13th March 2020



This document is not valid without its technical annex, whose number coincides with the number of certificate.

LGAI Technological Center, S.A. (APPLUS) Campus UAB s/n – Ronda de la Font del Carme, s/n E - 08193 Bellaterra (Barcelona) T +34 93 567 20 00 www.appluslaboratories.com



Technical Annex Ed. 1 13/03/2020

TECHNICAL ANNEX

APF-1692

Essential characteristics	Clauses in this European Standard	Mandated level(s) or class(es)
Response delay	4.1.1	NA
- Opening under wind load within a given time; - Opening under snow load within a given time.		NA
Operational reliability - Application categories; - Motor rating.	4.2.2	 Thermally uninsulated Converter feed Dual purpose use To use inside/outside smoke reservoir Vertical direction of motor shaft.
	4.2.3	NPD
Effectiveness of smoke/hot gas extraction: - Gas flow and pressure maintenance during smoke and heat extraction test.	4.3.2	+/-20% (P _S)
Resistance to fire	4.4	F ₄₀₀ (120)
Ability to open under environmental conditions - Opening under wind load within a given time;	4.5	NA
- Opening under snow load within a given time,		NA
Durability of operational reliability	4.6	NPD

PASS; NPD = No Performance Determined; NA = Not Applicable

PRODUCT

1.- Application:

- Extractor tested inside the furnace.
- Extractor F400 (120). Tested during 120 min.
- Vertical inlet and horizontal outlet of the direction of air flow.
- 7 Galvanized steel blades.

2.- Characteristics:

Motor: 90S-08/04 by WEG
Construction size: 90S
Rated frequency: 50 Hz
Rated Voltage motor: 400 V

• Polarity: 8/4

3.- Accessories:

- The impeller is coupled directly with the electric motor.
- The motor is plugged to electric net by means of high temperature resistant cable model VSH 1200.
- Protection grid.
- · Power terminal.
- · Frequency converter